







# Increased flexibility and power-production from biomass through material development and corrosion prediction

















Loli Paz, Johan Eklund, Sedi Bigdeli, Torbjörn Jonsson (CTH)
Søren Aakjær Jensen (Ørsted)
Rickard Shen, Susanne Selin (Kanthal)
Laura Rioja-Monllor (SMT)

Hanna Kinnunen, Davide Fantozzi (Valmet Technologies Oy)
John Hald, Kristian Vinter Dahl (DTU)
Bertil Wahlund (Energiforsk)











### Goal

The overall goal of the project is to increase the efficiency and flexibility/predictability of power generation from biomass.

#### The scientific goals of the project:

- Determine the *applicability* and *limitations of aluminium* oxide forming materials for improved biomass conversion effect, as well as *their comparison* with *existing materials*.
- Scale up lab-probe-fixed installation tests predict impact of e.g. material and temperature on lifetime of key components. Implement thermodynamic-kinetic modelling of oxidation in complex environments.



#### **INCREASED POWER PRODUCTION FROM BIOMASS**

Alumina forming materials – biomass environment

#### **INCREASED FLEXIBILITY – BIOMASS POWER PRODUCTION**




#### **INCREASED POWER PRODUCTION FROM BIOMASS**

Alumina forming materials – biomass environment

#### **INCREASED FLEXIBILITY – BIOMASS POWER PRODUCTION**



# Research strategy – a two pronged approach



Collaboration with HTC1a

# **Strategy – model alloys**

Tailor made model alloys







**Ranking** model alloys






Lab – collaboration with **HTC1a** 


Most promising model alloys






Corrosion tests in the boiler





20 µm

30 µm




#### **At lower Temperatures**

- Metastable forms of alumina may form
- Not as protective as α-alumina



## Research strategy – a two pronged approach



Collaboration with HTC1a Teamwork 2




## **Strategy – model alloys**

Characterize the deposit at different positions/temperatures

Expose the most promising model alloys (probe rings in the boiler – 168h/2000h)

- Best primary AND secondary protection!


Compare oxidation resistance with existing materials







# Field exposure - Skærbæk




Materials – 168h

- 347H
- 310
- Sanicro 25
- 347H with thermally sprayed with Fe12.4Cr3.7Al1.3Si
- Fe12.4Cr3.7Al1.3Si
- Fe10Cr4Al0Si
- Fe10Cr4Al1Si
- Fe10Cr3Al2Si




# **Material temperature**

Influence on corrosion attack



Low flue gas temperature



Sanicro 25


Fe10Cr4Al0Si



# Alloy composition (Si-effect)

Influence on corrosion resistance







#### **General remarks:**

- The operating parameters of the boiler (fuel, temperature etc.) resulted in a **very mild environment** 
  - Minor corrosion attack
  - IC analysis showed very low Cl concentration in all cases (<1 wt%)</li>
- Longer exposures needed to achieve a better understanding of the influencing parameters

#### **Material temperature:**

- The corrosion attack was slightly higher at 600 °C
- SEM analysis indicated increased amount of CI in deposit at the lower material temperature (600 °C)
- IC analysis showed very low CI concentration in deposit at both material temperatures

#### Flue gas temperature:

- SEM and IC showed minor or no influence of flue gas temperature on the amount of CI in the deposit
- No clear effect of flue gas temperature on the extent of corrosion attack

#### Alloy composition:

- In average, the FeCrAl alloys (more highly alloyed) behaved better than the stainless steels
  - Were able to better withstand presence of CI
- Indication of improved corrosion behaviour with Si-addition
- Coating (FeCrAI) showed great corrosion resistance
  - No oxide formation detected
  - Minimal material loss



#### **INCREASED POWER PRODUCTION FROM BIOMASS**

Alumina forming materials – biomass environment

#### **INCREASED FLEXIBILITY – BIOMASS POWER PRODUCTION**



#### **INCREASED POWER PRODUCTION FROM BIOMASS**


Alumina forming materials – biomass environment

#### **INCREASED FLEXIBILITY – BIOMASS POWER PRODUCTION**

# New boiler - Superheater test tube installations or tested



- Four test tube materials installed to the tertiary superheater
- Straight tubes, hottest part of the tertiary superheater




Material type	Grade	Tube size
347H	X7CrNiNb18-10	38,0 x 6,3 mm
347HFG	X8CrNi19-11	38,0 x 7,1 mm
310HCbN	SA-213 TP310HCbN	38,0 x 4,5 (min) mm
304HCu	KA-SUS304J1HTB	38,0 x 8,0 (min) mm






### Characterize the oxide microstructure in lab/probe/fixed installed samples


modelling perspective














168h





### **Characterize the oxide microstructure – modelling perspective**
















### Characterize the oxide microstructure – modelling perspective





#### **INCREASED POWER PRODUCTION FROM BIOMASS**

Alumina forming materials – biomass environment

#### **INCREASED FLEXIBILITY – BIOMASS POWER PRODUCTION**



### Goal

The overall goal of the project is to increase the efficiency and flexibility/predictability of power generation from biomass.

#### The scientific goals of the project:

- Determine the applicability and limitations of aluminium oxide forming materials for improved biomass conversion effect, as well as their comparison with existing materials.
- Scale up lab-probe-fixed installation tests predict impact of e.g. material and temperature on lifetime of key components. Implement thermodynamic-kinetic modelling of oxidation in complex environments.